

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7170-0694:130 Page 1 of 1

CATEGORY: Control Units (High Rise)

LISTEE: Fire Control Instruments, 301 2nd Avenue, Waltham, MA 02451-1133
Contact: Anthony J. Shalna (781) 487-0088

DESIGN: Model FIREVAC/FC-72 system. Local, auxiliary, remote station and proprietary service; waterflow detection. Suitable for use as a stand- alone voice communication/evacuation system. Refer to listee's data sheet for detailed product description and applicable codes and ordinances. System components:

OCC	SCM	PS-6
ACM	MT-250C/-60C/-125C	FFI
MCB	DRM	CCB-S/-D
MCB-S/-D	AIB	MTH
RPA	TAM	MCH
MBH	THC	MIC
SCM-S/-D	DCS-L/-R	FFI-M
MBI-L/-R	ACM-/O	MBA-R/-LR
RTM-SW	RTM-TP	RTM-CH
RTM-HN	PASM	MB-PASM
PA-60/-125/250	MBS-BL/-BR/-AL/-AR	

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed as a control unit in high-rise structures when used in conjunction with Models FC-72 or FC-72-DL system (CSFM Listing No. 7165-694:001) and separately listed compatible initiating and indicating devices.

*This control unit can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1996 Edition. Refer to manufacturer's Installation Manual for details.

*Corrected 09-14-98



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **MAY 23, 2001**

*Listing Expires **June 30, 2002***

Authorized By: **BEN HO, Supervising Deputy
Program Manager**